



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

September 25, 2006
Subject: **Madison**
Project No. NH-9196(00)E
Pin No. 9196.00
Amendment No. 2

Dear Sir/Ms:

Please make the following changes to the Bid Documents:

In the Plans

On Plan sheet twenty-nine of one hundred seventeen in the cross-section drawing for station 1+460.000, within the pipe drawing DELETE "OPTION III" and REPLACE with "RCP CLASS III". Make this change in pen and ink.

The following questions have been received.

Question: For Item 308.35 is a distribution truck method of application acceptable, or is a reclaimer with a foam application kit required?

Response: "Special Provision, Section 308, Full Depth Recycled Pavement" calls for it to go through the reclaimer, a distributor truck is not allowed.

Question: On the cross-sections for station 1+460.000 there are two 750MM Option III pipes shown, but on the Plan/Profile sheet (sheet #9) they are called out as RCP Class III. Please clarify.

Response: See earlier change in this amendment.

Consider this change and information prior to submitting your bid on September 27, 2006.

Sincerely,

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER